

SOLICITATION: W91ZRS-04-Q-0018
AMENDMENT 001
EHRR LAND CLEARING
JULY 12, 2004

This amendment provides answers to questions that came about as a result of the site visit held on Friday, August 6, 2004.

1. Are there any requirements to notify and get approval from the East Haven In-Land Wetland commission for this project?

Answer: When the proponent is a state agency, the state Inland Wetlands and Watercourses Act is enforced by the CT DEP instead of the towns. No approval was needed by DEP. The trimming and cutting of vegetation is allowable in a wetland if: hand tools are used only, if there is no ground disturbance (grubbing, stumping, etc.), and if the removal is only "maintenance" and not "clear-cutting".

2. Has there been a determination of the load capacity of the bridge?

Answer: On December 21, 2001, an engineering firm recommended limiting the live load to 6 tons.

3. Will GC Supervision be required on site full time?

Answer: A full time GC Supervisor will not be required.